



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From  
The District fire officer,  
Rangareddy Division.

To,  
salman babukhan,  
glendale academy international,

Ack. No.353240002021 Dated:27/01/2021

Sir,

Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Glendale Academy International,h.no=7-109,sy.no 96/4,96/6,radhanagar bandlaguda jagir,village/-Bandlaguda Jagir/Gandipet/Rangareddy , – Regarding.**



Ref:

1. Acknowledgement No 353240002021
2. This Office NOC for Occupancy Ack/RC No.1463/A2/2014 dt.27/01/2021
3. Non Multi storeyed Building Inspection Committee Report, Ack. No. 353240002021, dt. 27/01/2021

\*\*\*\*\*

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Glendale Academy International,h.no=7-109,sy.no 96/4,96/6,radhanagar bandlaguda jagir,village/-Bandlaguda Jagir/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **2 Ground, 3 Floors**, with a height of **13.20 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level Occupancy**.
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **2 Ground, 3 Floors**, with a height of **13.20 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level Occupancy**

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	4.00	8.00
2	South	4.00	8.00
3	East	4.00	8.00
4	West	4.00	7.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	6
2	Entry Gate Head Clearance	5.00	6
3	Exit Gate Width	4.50	6
4	Exit Gate Head Clearance	5.00	6.00

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	24.00	24.00
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	21.00	21.00

6) Stair.Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	2.30	1	Ground	Terrace

*[Signature]*

*[Signature]*

2	External staircases	1.50	1	Ground	Terrace
3	Internal staircases	0.00	0		
4	External staircases	0.00	0		
5	Internal staircases	0.00	0		
6	External staircases	0.00	0		
7	Internal staircases	0.00	0		
8	External staircases	0.00	0		

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Lower Ground	878.93	EDUCATIONAL B-1 Schools up to senior secondary level	170.00	3.80	3.80
2	Ground	1691.00	EDUCATIONAL B-1 Schools up to senior secondary level	170.00	3.80	3.80
3	1st Floor	1618.54	EDUCATIONAL B-1 Schools up to senior secondary level	170.00	3.80	3.80
4	2nd Floor	1729.53	EDUCATIONAL B-1 Schools up to senior secondary level	170.00	3.80	3.80
5	3rd Floor	1729.53	EDUCATIONAL B-1 Schools up to senior secondary level	170.00	3.80	3.80

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Lower Ground	4.00	3.00	0.00	3.00	0.00
2	Ground	4.00	3.00	0.00	3.00	0.00
3	1st Floor	4.00	3.00	0.00	3.00	0.00
4	2nd Floor	4.00	3.00	0.00	3.00	0.00
5	3rd Floor	4.00	3.00	0.00	3.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	20	20
First Aid Hose Reel	15	15
Down Comer	3	3
Manually Operated Electronic Fire Alarm Systems	15	15
Terrace Tank over Respective Tower Terrace in Litres	20000	20000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm <sup>2</sup>	900	900

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the Recommendation of the Inspection Committee, issuance of the Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with Glendale Academy International, h.no=7-109, sy.no 96/4,96/6, radhanagar bandlaguda jagir, village/-Bandlaguda

